

Energy performance certificate (EPC)

3 The Courtyard Penmount TRURO TR4 9AA	Energy rating	Valid until: 5 December 2027
	E	Certificate number: 8893-6422-5869-0046-1906

Property type **Mid-terrace house**

Total floor area **59 square metres**

Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy rating and score

This property's energy rating is E. It has the potential to be A.

[See how to improve this property's energy efficiency.](#)

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D
the average energy score is 60

Score	Energy rating	Current	Potential
92+	A		117 A
81-91	B		
69-80	C		
55-68	D		
39-54	E	41 E	
21-38	F		
1-20	G		

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Granite or whinstone, as built, no insulation (assumed)	Very poor
Roof	Pitched, 150 mm loft insulation	Good
Window	Fully double glazed	Average
Main heating	Electric storage heaters	Average
Main heating	Electric storage heaters	Average
Main heating control	Automatic charge control	Average
Main heating control	Manual charge control	Poor
Hot water	Electric immersion, off-peak	Very poor
Lighting	Low energy lighting in 33% of fixed outlets	Average
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Room heaters, electric	N/A

Primary energy use

The primary energy use for this property per year is 584 kilowatt hours per square metre (kWh/m²).

Additional information

Additional information about this property:

- Dual electricity meter selected but there is also an electricity meter for standard tariff
The assessment has been done on the basis of an off-peak electricity tariff. However some heating or hot water appliances may be on the standard domestic tariff.
- Stone walls present, not insulated
- Dwelling may be exposed to wind-driven rain

How this affects your energy bills

An average household would need to spend **£1,129 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £692 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2017** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 8,586 kWh per year for heating
- 2,151 kWh per year for hot water

Impact on the environment

This property's environmental impact rating is F. It has the potential to be A.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO₂) they produce each year.

Carbon emissions

An average household produces **6 tonnes of CO₂**

This property produces **5.8 tonnes of CO₂**

This property's potential production **-0.3 tonnes of CO₂**

You could improve this property's CO₂ emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Steps you could take to save energy

Step	Typical installation cost	Typical yearly saving
1. Internal or external wall insulation	£4,000 - £14,000	£364
2. Floor insulation (solid floor)	£4,000 - £6,000	£37
3. Increase hot water cylinder insulation	£15 - £30	£39
4. Low energy lighting	£30	£23
5. High heat retention storage heaters	£1,200 - £1,800	£156
6. Solar water heating	£4,000 - £6,000	£52

Step	Typical installation cost	Typical yearly saving
7. High performance external doors	£1,000	£21
8. Solar photovoltaic panels	£5,000 - £8,000	£326
9. Wind turbine	£15,000 - £25,000	£602

Advice on making energy saving improvements

Get detailed recommendations and cost estimates: www.gov.uk/improve-energy-efficiency

Help paying for energy saving improvements

You may be eligible for help with the cost of improvements:

- Free energy saving improvements: [Home Upgrade Grant \(www.gov.uk/apply-home-upgrade-grant\)](http://www.gov.uk/apply-home-upgrade-grant)
- Insulation: [Great British Insulation Scheme \(www.gov.uk/apply-great-british-insulation-scheme\)](http://www.gov.uk/apply-great-british-insulation-scheme)
- Heat pumps and biomass boilers: [Boiler Upgrade Scheme \(www.gov.uk/apply-boiler-upgrade-scheme\)](http://www.gov.uk/apply-boiler-upgrade-scheme)
- Help from your energy supplier: [Energy Company Obligation \(www.gov.uk/energy-company-obligation\)](http://www.gov.uk/energy-company-obligation)

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Vincent Falco
Telephone	01872 553685
Email	vincefalco@googlemail.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/020195
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Assessor's declaration	No related party
Date of assessment	6 December 2017
Date of certificate	6 December 2017
Type of assessment	RdSAP