Find an energy certificate (/)

#### English | <u>Cymraeg</u>

# Energy performance certificate (EPC)

16 Peckett Close HUDDERSFIELD HD3 4DQ	Energy rating	Valid until:	11 September 2033
	D	Certificate number:	0380-2322-3310 <mark>&amp;</mark> -2197- 8075

**Property type** 

Semi-detached house

Total floor area

81 square metres

### **Rules on letting this property**


Properties can be let if they have an energy rating from A to E.

You can read guidance for landlords on the regulations and exemptions (https://www.gov.uk/guidance/domestic-privaterented-property-minimum-energy-efficiency-standard-landlord-guidance).

# **Energy rating and score**

This property's energy rating is D. It has the potential to be B.

See how to improve this property's energy efficiency.



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

# Breakdown of property's energy performance

#### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, filled cavity	Average
Roof	Pitched, 250 mm loft insulation	Good
Roof	Roof room(s), limited insulation (assumed)	Poor
Window	Fully double glazed	Average

23/06/2025, 18:54

Energy performance certificate (EPC) – Find an energy certificate – GOV.UK

Feature Description		Rating	
Main heating	Boiler and radiators, mains gas	Good	
Main heating control	Programmer, room thermostat and TRVs	Good	
Hot water	From main system	Good	
Lighting	Low energy lighting in all fixed outlets	Very good	
Floor	Solid, no insulation (assumed)	N/A	
Secondary heating	None	N/A	

#### Primary energy use

The primary energy use for this property per year is 251 kilowatt hours per square metre (kWh/m2).

#### About primary energy use

# How this affects your energy bills

An average household would need to spend £1,854 per year on heating, hot water and lighting in this property. These costs usually make up the majority of your energy bills.

You could save £395 per year if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2023** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

#### Heating this property

Estimated energy needed in this property is:

- 11,432 kWh per year for heating
- 2,115 kWh per year for hot water

# Impact on the environment

This property's environmental impact rating is D. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

#### **Carbon emissions**

An average household produces	6 tonnes of CO2
This property produces	3.6 tonnes of CO2
This property's potential production	1.9 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

# Steps you could take to save energy

Do I need to follow these steps in order?

#### Step 1: Room-in-roof insulation

Typical installation cost	£1,500 - £2,700
Typical yearly saving	£195
Potential rating after completing step 1	71 C

#### Step 2: Floor insulation (solid floor)

Typical installation cost	£4,000 - £6,000
Typical yearly saving	£117
Potential rating after completing steps 1 and 2	72 C

#### Step 3: Solar water heating

Typical installation cost	£4,000 - £6,000
Typical yearly saving	£82
Potential rating after completing steps 1 to 3	74 C

#### Step 4: Solar photovoltaic panels, 2.5 kWp

Typical installation cost	£3,500 - £5,500
Typical yearly saving	£609
Potential rating after completing steps 1 to 4	84 B

#### Advice on making energy saving improvements

Get detailed recommendations and cost estimates

#### Help paying for energy saving improvements

You may be eligible for help with the cost of improvements:

- Insulation: Great British Insulation Scheme
- Heat pumps and biomass boilers: Boiler Upgrade Scheme
- Help from your energy supplier: Energy Company Obligation

# Who to contact about this certificate

#### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Jason Carroll
Telephone	07828 950341 🌜
Email	jasonc.carroll@yahoo.co.uk

#### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/012745
Telephone	01455 883 250 🌜
Email	enquiries@elmhurstenergy.co.uk

#### About this assessment

Assessor's declaration

No related party

Date	of	assessment
------	----	------------

Date of certificate

12 September 2023

12 September 2023

Type of assessment

RdSAP

# Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here please contact us at <u>mhclg.digital-services@communities.gov.uk</u> or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.

<u>Help (/help)</u> <u>Accessibility (/accessibility-statement)</u> <u>Cookies (/cookies)</u> <u>Give feedback (https://forms.office.com/e/KX25htGMX5)</u> Service performance (/service-performance)

#### OGL

All content is available under the <u>Open Government</u> <u>Licence v3.0 (https://www.nationalarchives.gov.uk/doc/open-</u> government-licence/version/3/), except where otherwise stated



© Crown copyright (https://www.nationalarchives.gov.uk/information-management/reusing-public-sector-information/uk-government-licensing-framework/crown-copyright/)